

WASHINGTON TOWNSHIP MUNICIPAL UTILITIES AUTHORITY

SCHEDULE I
EQUIVALENT DOMESTIC CONSUMER UNITS

<u>Type of Structure</u>	<u>Units</u>
1) Single Family, Twin, Townhouse Residential	1
2) Rental or Condominium Apartment Unit and Residential Trailer	.7
3) Senior Citizen Multiple Unit Structure	.7
4) Hotel or Motel (Per living unit)	.5
5) Service Station (Without car washing facilities)	1
6) Service Station (With car washing facilities)	2
7) Supermarket	10
8) Clubs, Societies, Social Organizations	1
9) Clubs, Societies, Social Organizations (With bar and/or dining facilities)	3
10) Churches	1
11) Commercial Garage (With water fixtures)	1
12) Eating Establishments:	
a) Take -Out Restaurant (without seating facilities)	2
b) Fast Food, Soda Fountain, Luncheonette 1 – 25 seating capacity	1
Each additional 20 seats or segment thereof	1
c) Diner, Tavern, Restaurant:	
1 - 50 seating capacity	3
each additional 15 seats or segment thereof	1
13) Health Care Institution other than hospital ie. Nursing or Convalesent Home, Assisted Living (100 gpd per bed)	.45
14) Office Building (per each 3,000 square feet of gross floor area or segment thereof)	1
15) Laundromat or Self-Service Laundry (per each washer)	.2
16) Swim Clubs (wastewater from fixtures only)	2
SWIMMING POOL DRAINS MAY NOT BE CONNECTED TO THE SANITARY SEWER SYSTEM.	

WASHINGTON TOWNSHIP MUNICIPAL UTILITIES AUTHORITY

- 17) **Retail & General Commercial Business:**
 - a) **Per first 3,000 square feet of gross floor area or segment thereof** **1**
 - b) **Per each additional 5,000 square feet of gross floor area or segment thereof** **1**
- 18) **Warehouse (per each 5,000 square feet of gross floor area or segment thereof)** **1**
- 19) **Theater:**
 - Each 100 seats or segment thereof** **1**
- 20) **Drive-In Theater:**
 - 1 to 36 vehicle stalls** **2**
 - Each additional 18 stalls or segment thereof** **1**
- 21) **Industrial or manufacturing plant without industrial waste (per each 3,000 square feet of gross floor area)** **1**

The WTMUA reserves the right to use a different parameter should the industrial user incorporate a large quantity of water either in their product manufacturing or clean-up requirements.
- 22) **Public Building** **2**
- 23) **School (per each 30 pupils and faculty)** **1**
- 24) **Attached Business to a Residential Unit:**
 - When a residence has an attached unit for a business that has a walk in clientele, it is classified as a business.** **1.5**
- 25) **Hospital (175 gpd per bed)** **.80**
- 26) **A commercial property user who desires a change in use (intensified use) shall use this chart in calculating his equivalent DCU. This rate is then used in calculating differential between the old and new DCU (additional Connection Fee).**

When establishment will serve more than one use, the multiple use shall be considered in determining demand.

In the event a business or structure is not described in this schedule, the WTMUA shall determine the minimum equivalent domestic consumer units.